

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1591:104 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Model 1534-A001 pull box. Non-coded, key operated manual station. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a non-coded, key operated manual station. Approved for indoor use only. Model 1534-A001 is for use in institutional occupancies when manual pull type fire alarm stations are not suitable.

NOTE:

1. Authority Having Jurisdiction shall be consulted prior to installation.
2. Formerly 7150-1388:176

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager